NFPA Logo
Removed

**Errata**

# NFPA 30

# Flammable and Combustible Liquids Code

**2003 Edition**

**Reference: Table 6.8.2(k)**
**Errata No.: 30-03-2**

The Technical Committee on Flammable and Combustible Liquids Code notes the following errors in the 2003 edition of NFPA 30, *Flammable and Combustible Liquids Code*.

1. *In Table 6.8.2(k), the title of the table should read:*

   **Table 6.8.2(k) Water Sprinkler Protection for Bulk or Palletized Metal Containers of Unsaturated Polyester Resin (UPRs) Containing up to 50 % by weight Class IC, Class II, or Class IIIA Liquid Constituents *(See 6.8.1.7.)***

2. *In Table D.2(k), the "Technical Justification and Test Identifier" should read:*

   "Results of Tests S-77 through S-82"

**Issue Date: April 18, 2006**

Copyright © 2006 all Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION